



AGENDA MEMO

5/16/2017 Agenda

TO: Honorable Mayor and City Council

FROM: Jacob Speer, Director of Public Works

SUBJECT: Consider approval of a proposal from Kimley-Horn for Engineering Services associated with the renovation and repairs of the Northwest Highway Elevated Water Storage Tank

BACKGROUND:

The Northwest Highway Elevated Water Storage Tank was built in 1996 and has been in service since 1997. Annual inspections have not identified major corrosion or locations of structural failure below the water line, but the coating system is no longer providing sufficient protection and is degrading. Additionally the cathodic protection system no longer functions and needs to be replaced and the most recent inspection found failures in the tank above the water line which require repair or replacement.

The attached proposal from Kimley-Horn in the amount of \$189,900 provides for engineering design, assistance with project bidding, and project construction administration and inspection.

RECOMMENDATION:

Staff recommends approval of the proposal by Kimley-Horn for Engineering Services associated with the renovation and repairs of the Northwest Highway Elevated Water Storage Tank in the amount of \$189,900.